



SECURITY GATE CONFIDENCE TEST REPORT

Camas-Washougal Fire Marshal's Office

Property Name: _____ Date Tested: _____

Notice: This test must be performed and signed annually in compliance with the Camas and Washougal Municipal Gate Codes.

TEST ITEM

YES NO N/A

Knox Access: Approved Knox Box, Toggle, or Key Switch (preferred) installed?

Access Codes: Programmed with Fire/Police/Public Works codes?

Strobe Activation: Gate opens via approved handheld strobe testing device?

Opticom: Opticom sensor lens has been cleaned and tested?

Labeling: "Protocol" access label (#, *, or Key) is legible day and night?

Power Loss: Auxiliary power supply defaults gate to OPEN on power loss?

Gate Width: Minimum unobstructed width is at least 12 feet?

Turnaround: Approved turnaround provided adjacent to the gate?

Signage: Visible sign indicating "Locked Gate Ahead" is present?

Pedestrian Access: Separate pedestrian access is provided and unlocked?

Tire Punctures: Are tire punctures (spikes) present? *(Prohibited locally)*



SECURITY GATE CONFIDENCE TEST REPORT

Camas-Washougal Fire Marshal's Office

Residential Access: Activation via phone, intercom, or magnetic card functional?

Keypad Reach: Keypad mounted at least 6ft from moving gate parts (UL 325)?

Manual Override: Emergency release is operational?

COMMENTS & DEFICIENCIES

Detail any "No" answers or required repairs below. If repairs are needed, the gate must remain locked in the open position until fixed.

PLEASE PROVIDE HOA CONTACT INFORMATION

HOA/Property Name: _____

Primary Contact: _____ **Phone:** _____

Email: _____

SIGNATURE

Company: _____

Technician: _____ **Phone:** _____

Signature: _____ **Date:** _____

(Signature confirms all items were tested per IFC and municipal codes.)