

**ADDENDUM NO. 2  
TO THE  
SPECIFICATIONS AND CONTRACT DOCUMENTS**

**for**

**City Project No. S1040**

**Camas Blower Improvements Project – Equipment Purchase**  
May 2, 2024

IMPORTANT:            *This addendum must be signed and submitted with the proposal.*

TO ALL PLANHOLDERS:

The following changes, additions, and/or deletions are made a part of the contract documents and bid specifications for the *Camas Blower Improvements Project – Equipment Purchase*, City of Camas Project No. S1040 as fully and completely as if the same were set forth therein:

**CLARIFICATIONS** – See the following clarifications in response to bidder questions:

*In response to questions raised by potential Bidders regarding the blower units, the minimum flow with one machine operating is 675 SCFM and the total flow with all machines operating provide under this procurement is 2665 SCFM, per the contract documents.*

Receipt of this addendum is hereby acknowledged:

---

Authorized Signature